

**Columbia County**  
**Fire Service Road Improvement Inspection**  
**For Roads over 150 feet in Length**

Owner Name \_\_\_\_\_ Phone (     ) \_\_\_\_\_ Email \_\_\_\_\_

Property Address \_\_\_\_\_ **OR** Tax Map Number \_\_\_\_\_

Applicant \_\_\_\_\_ Phone (     ) \_\_\_\_\_ Email \_\_\_\_\_

**(If other than the Property owner)**

YES    NO    N/A

- All paperwork identified and complete.
- Is the grade within the applicable standard (Less than 12 % or up to 15% for less than 200 feet)? **OFC 503.2.7 & D103.2**
- Is paving required for this driveway? **County Ordinance**
- Is the driveway over 17%? If so an NFPA 13D system is required. **County Ordinance, OFC 503.2.7 & D103.2**
- If the driveway serve more than one home are address signs posted at the driveway and the house? **County Ordinance**
- If there is a bridge or culvert, Has the weight limit been posted? **OFC 503.2.6**
- Is the roadway subject to runoff? If so, has drainage been mitigated? **OFC D103.3.1**
- Is the driveway more than 400 feet?
- If so, are turnouts installed (20' wide by 40' long)? **County Ordinance**
- Has an emergency vehicle turnaround been installed or identified? **OFC 503.2.5 & D103.4**
- Is the roadway 12 feet wide with 4 feet of clearance on each side (20 feet total clearance)? **County Ordinance & OFC 503.2.1**
- Is the address posted on the building and access road? **OFC 505**
- If there is a locked access is a fire department approved lock or access been installed? **OFC 503.4, 503.6, 506 & D103.5**
- Is the angle of departure or approach within limits? **OFC 503.2.8**
- Is the vertical clearance at 13' 6"? **OFC 503.2.1**
- All turning radius greater than 45 feet on corners & curves of more than 30 degrees? (Gravel required full 20' width) **OFC D103.3**
- If there is a bridge, are the weight limitations posted on the entrance side? **County Ordinance OFC 503.2.6**

Comments and required Improvements: \_\_\_\_\_

First Inspection Fire Official: \_\_\_\_\_ Date: \_\_\_\_\_ Agency: \_\_\_\_\_

Re-Inspection Fire Official: \_\_\_\_\_ Date: \_\_\_\_\_ Agency: \_\_\_\_\_

Final Inspection Fire Official: \_\_\_\_\_ Date: \_\_\_\_\_ Agency: \_\_\_\_\_

\_\_\_\_\_ Improvement needed, access not granted

\_\_\_\_\_ Temporary Access Granted with re-inspection prior to occupancy

\_\_\_\_\_ The roadway improvements meet the access for fire service equipment.